Material Prüfinstitut
Hellberg GmbH

Artlenburger Landstraße 39 - 41
21365 Adendorf

Tel.: +49 4131 88 43 947
Fax: +49 4131 88 43 948
Email: info@mpi-gmbh.de
Internet: www.mpi-gmbh.de

Test certificate No.: 12 6352 - S / 11

Date: 15.06.2011

Customer:	Asphalt Art International AG Riedstraße 7 6330 Cham Switzerland
Order No.:	n.n.
Date of order:	01.06.2011
Type of test:	Testing of floorcoverings in accordance with DIN 51130, Slip Resistance ”Ramp Test”.
Testing material:	
Trade name: (declaration by customer)	"Asphalt Art", Asphalt film, unprinted applied on a bushhammered granite surface
Format of test item: (according to DIN 51130 / BGR181)	100 cm x 50 cm (Length x Width)
Surface structure:	smooth, fine rough
Format of single tile:	various, endless coil

The pages 1 and 2 show the complete test result. They may just be published together

Test

Date of test:	15.06.2011
Standards / regulations:	**DIN 51130 (Ausgabe 2004-06):** Bestimmung der rutschhemmenden Eigenschaft – Arbeitsräume und Arbeitsbereiche mit erhöhter Rutschgefahr. **BGR 181:** Merkblatt für Fußböden in Arbeitsräumen und Arbeitsbereichen mit Rutschgefahr.
Joint width of item for testing:	**0** cm

Test result:

Average angle:	**24,6°**
Average displacement:	**not tested**
Classification:	**R 11**
Classification of displacement:	**not applicable**

Validity of this certificate

Owing to possible changes in regulations (test / standards) and technical innovations, the validity of this certificate is limited for the duration of 5 years until the 15.06.2016.

The test results are only valid for produts which are identical with the tested item. The correlation between the item tested and the production lot is not controlled ny MPI Hellberg GmbH!

General informations

Certificates may only be copied and published with permission of the MPI Hellberg GmbH without any changes.
The publishing and copying of shortened versions is only permitted after consulting with MPI Hellberg GmbH.

MPI - MATERIAL PRÜFINSTITUT HELLBERG GMBH LABORATORIUM FÜR GLASCHEMIE

MPI Hellberg GmbH
(Institutsleitung Jens Hellberg)